

PARTICLE SIZE DISTRIBUTION TEST


BS EN 933-1 Series

Wet Sieve:

Classification for Acceptable Earthworks

Sample Number: 1

Classification Type: 0/4mm



BS Test Sieve mm	Percentage Passing %	Lower Limit %	Upper Limit %
500	100		
300	100		
125	100		
90	100		
80	100		
63	100		
40	100		
31.5	100		
20	100		
16	100		
8	100	100	100
6.3	100	95	100
4	97	88	98
2.8	94		
2	92		
1	84	56	96
0.5	65	30	70
0.3	45		
0.25	37	0	40
0.125	15		
0.063	1	0	3

Remarks:



Port Salford

Contract No.:

PSL23/5089

Client Ref:

28/06/2023